

Martin, Thornton E

From: Martin, Thornton E
Sent: Tuesday, January 24, 2017 3:00 PM
To: 'gayle.fratto@mail.wvu.edu'; 'brian.lemme@mail.wvu.edu'
Cc: Mckeone, Beverly D (Beverly.D.Mckeone@wv.gov)
Subject: WV DAQ Permit Application Complete for West Virginia University (HSC Campus)

**RE: Application Status: Complete
West Virginia University (HSC Campus)
Permit Application No. R13-3352
Plant ID No. 061-00230**

Ms. Fratto:

Your application for a construction permit for the five (5) Emergency Generator Sets at the Health Science Center Campus was received by this Division on December 08, 2016 and assigned to the writer for review. On December 12, 2016, the DAQ received the application fee. On December 15, 2016, the DAQ received the original affidavit of publication and on January 05, 2017, the DAQ received the requested Manufacturer's Data Sheets. Upon further review of said application, it has been determined that the application is complete and, therefore, the statutory review period commenced on January 24, 2017.

In the case of this application, the agency believes it will take approximately 90 days to make a final permit determination.

This determination of completeness shall not relieve the permit applicant of the requirement to subsequently submit, in a timely manner, any additional or corrected information deemed necessary for a final permit determination.

Should you have any questions, please contact me at (304) 926-0499 ext.1212 or reply to this email.

Thornton E. Martin Jr.
Permit Engineer
Division of Air Quality
601 57th Street, SE
Charleston, WV 25304
Phone: 304-926-0499 X1212
Fax: 304-926-0479



Entire Document
NON-CONFIDENTIAL

Martin, Thornton E

From: Brian Lemme <Brian.Lemme@mail.wvu.edu>
Sent: Thursday, January 5, 2017 9:36 AM
To: Martin, Thornton E
Cc: Gayle Fratto
Subject: RE: WV DAQ Permit Application Incomplete for West Virginia University (HSC Campus)
Attachments: Attachment D-Regulatory-rev.docx; G6-HSC DQFAA.pdf; G7-HSC DQFAB.pdf; G1-HSC CAT 3512B.pdf; G3-HSC CAT C18.pdf; G4-HSC DQCA Certification.pdf; G4-HSC DQCA.pdf; G6 and G7 DQFAA-DQFAB Cert.pdf

Mr. Martin,

Here is the revised attachment D showing the correct listings of the emergency generators. I have also attached the requested information about supporting data sheets and certification documents. Please let me know if there is any additional information you will need to complete the application process.

Thanks,

Brian M. Lemme, CESSWI, CPMSM
Environmental Health and Safety Specialist
Stormwater Specialist

West Virginia University
975 Rawley Lane
PO Box 6551
Morgantown, WV 26506

Office 304-293-8742
Cell 724-493-9203
Brian.Lemme@mail.wvu.edu

From: Martin, Thornton E [mailto:Thornton.E.Martin@wv.gov]
Sent: Wednesday, January 04, 2017 1:36 PM
To: Brian Lemme <Brian.Lemme@mail.wvu.edu>
Subject: RE: WV DAQ Permit Application Incomplete for West Virginia University (HSC Campus)

Hi Brian,

If you have the ability to scan the documents, you are welcome to email them. I just need clean, clear, legible copies for the file.

Thanks,

Thornton E. Martin Jr.
Permit Engineer
Division of Air Quality
601 57th Street, SE
Charleston, WV 25304

Entire Document
NON-CONFIDENTIAL

Phone: 304-926-0499 X1212

Fax: 304-926-0479



From: Brian Lemme [<mailto:Brian.Lemme@mail.wvu.edu>]

Sent: Wednesday, January 4, 2017 12:06 PM

To: Martin, Thornton E <Thornton.E.Martin@wv.gov>; Gayle Fratto <Gayle.Fratto@mail.wvu.edu>

Cc: McKeone, Beverly D <Beverly.D.Mckeone@wv.gov>

Subject: RE: WV DAQ Permit Application Incomplete for West Virginia University (HSC Campus)

Mr. Martin,

Thank you for notification of the incomplete requirements. I will review this section and compile the requested information.

Once the data is acquired, what would be the best process to submit the supporting documents?

Thanks,

Brian M. Lemme, CESSWI, CPMSM

Environmental Health and Safety Specialist

Stormwater Specialist

West Virginia University

975 Rawley Lane

PO Box 6551

Morgantown, WV 26506

Office 304-293-8742

Cell 724-493-9203

Brian.Lemme@mail.wvu.edu

From: Martin, Thornton E [<mailto:Thornton.E.Martin@wv.gov>]

Sent: Wednesday, January 04, 2017 11:43 AM

To: Gayle Fratto <Gayle.Fratto@mail.wvu.edu>; Brian Lemme <Brian.Lemme@mail.wvu.edu>

Cc: McKeone, Beverly D <Beverly.D.Mckeone@wv.gov>

Subject: WV DAQ Permit Application Incomplete for West Virginia University (HSC Campus)

**RE: Application Status: Incomplete
West Virginia University (HSC Campus)
Permit Application No. R13-3352**

Ms. Fratto:

Your application for a construction permit for the five (5) Emergency Generator Sets at the Health Science Center Campus was received by this Division on December 08, 2016 and assigned to the writer for review. Upon initial review of said application, it has been determined that the application as submitted is incomplete based on the following items:

1. The Regulatory Discussion (Attachment D) does not appear to match other supporting documents within the application. The Engine Data Sheets indicate that all five engines are EPA Certified engines and only one engine was manufactured prior to 2006.
2. Based on the requirements of 45CFR60 Subpart IIII—*Standards of Performance for Stationary Compression Ignition Internal Combustion Engines* and 40CFR63 Subpart ZZZZ—*National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines* the following information is requested:

Engine Data Sheet: Year, Make, Model, Serial No., BHP/RPM, fuel throughput, Engine Type, APCD Type and Potential Emissions Data Reference.

3. EPA Certificate of Conformity for each Certified Engine or the Manufacturers Data Sheet showing the engine emissions meet EPA Standards for the Year/Make/Model.

Please address the above deficiencies in writing within fifteen (15) days of the receipt of this email. Application review will not commence until the application has been deemed to be technically complete. Failure to respond to this request in a timely manner may result in the denial of the application.

Should you have any questions, please contact me at (304) 926-0499 ext.1212 or reply to this email.

Thornton E. Martin Jr.

Permit Engineer

Division of Air Quality

601 57th Street, SE

Charleston, WV 25304

Phone: 304-926-0499 X1212

Fax: 304-926-0479



Martin, Thornton E

From: Martin, Thornton E
Sent: Wednesday, January 4, 2017 11:43 AM
To: 'gayle.fratto@mail.wvu.edu'; 'brian.lemme@mail.wvu.edu'
Cc: Mckeone, Beverly D (Beverly.D.Mckeone@wv.gov)
Subject: WV DAQ Permit Application Incomplete for West Virginia University (HSC Campus)

**RE: Application Status: Incomplete
West Virginia University (HSC Campus)
Permit Application No. R13-3352
Plant ID No. 061-00230**

Ms. Fratto:

Your application for a construction permit for the five (5) Emergency Generator Sets at the Health Science Center Campus was received by this Division on December 08, 2016 and assigned to the writer for review. Upon initial review of said application, it has been determined that the application as submitted is incomplete based on the following items:

1. The Regulatory Discussion (Attachment D) does not appear to match other supporting documents within the application. The Engine Data Sheets indicate that all five engines are EPA Certified engines and only one engine was manufactured prior to 2006.
2. Based on the requirements of 45CFR60 Subpart IIII—*Standards of Performance for Stationary Compression Ignition Internal Combustion Engines* and 40CFR63 Subpart ZZZZ—*National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines* the following information is requested:

Engine Data Sheet: Year, Make, Model, Serial No., BHP/RPM, fuel throughput, Engine Type, APCD Type and Potential Emissions Data Reference.

3. EPA Certificate of Conformity for each Certified Engine or the Manufacturers Data Sheet showing the engine emissions meet EPA Standards for the Year/Make/Model.

Please address the above deficiencies in writing within fifteen (15) days of the receipt of this email. Application review will not commence until the application has been deemed to be technically complete. Failure to respond to this request in a timely manner may result in the denial of the application.


Should you have any questions, please contact me at (304) 926-0499 ext.1212 or reply to this email.

Thornton E. Martin Jr.
Permit Engineer
Division of Air Quality
601 57th Street, SE
Charleston, WV 25304
Phone: 304-926-0499 X1212
Fax: 304-926-0479

Entire Document
NON-CONFIDENTIAL



PUBLISHER'S CERTIFICATE



vs.

STATE OF WEST VIRGINIA
COUNTY OF MONONGALIA

I Eric Wilson Advertising Director of
THE DOMINION POST, a newspaper of general circulation
published in the City of Morgantown, County and State
aforesaid, do hereby certify that the annexed

Legal Notice

was published in the said THE DOMINION POST once a week

for 1 successive weeks commencing on the

5th day of Dec., 2016 and ending on the

5th day of Dec., 2016

The publisher's fee for said publication is \$62.96

Given under my hand this 5th day of

December, 2016


(SEAL)

Advertising Director of THE DOMINION POST

Subscribed and sworn to before me this 5th

day of December, 2016

Notary Public of Monongalia County, W. Va.
My commission expires on the 13th day of
December 2019



010104347

AIR QUALITY PERMIT NOTICE Notice of Application

December 5

Notice is given that West Virginia University has applied to the West Virginia Department of Environmental Protection, Division of Air Quality, for a Construction Permit for emergency backup generators located at 1 Medical Center Drive, in Morgantown, in Monongalia County, West Virginia. The latitude and longitude coordinates are: 39.653415N 79.957355W

The applicant estimates the potential to discharge the following Regulated Air Pollutants will be:
24.505 tons per year (tpy) for Oxides of Nitrogen; 5.695 tpy for Carbon Monoxide; 6.043 tpy for Sulfur Dioxide; 1.400 tpy for Particulate Matter; 1.020 tpy for Volatile Organic Compounds; and 0.1140105 tpy for Formaldehyde.

Startup of operation began on or about 2004 or later. Written comments will be received by the West Virginia Department of Environmental Protection, Division of Air Quality, 601 57th Street, SE, Charleston, WV 25304, for at least 30 calendar days from the date of publication of this notice.

Any questions regarding this permit application should be directed to the DAQ at (304) 926-0499, extension 1250, during normal business hours.

Dated this the 5th day of December, 2016.

By: West Virginia University
Brian Lemme
EHS Specialist
975 Rawley Lane
Morgantown, WV 26506

Entire Document
NON-CONFIDENTIAL

1700063575

304-293-8742
Brian Lemme - WVU
air permit application fee
HSC Campus \$2,000.00
Fac. ID 061-00230

App # R13-3352
email
Brian.Lemme@mail.wvu.edu

WV DEP
601 57TH ST SE
CHARLESTON, WV 25304

SALE

MID: 5990 Store: 5430 Term: 7501
REF#: 00000004
Batch #: 232 RRN: 634721409652
12/12/16 16:42:33
NO IS WATCH INC W
Invoice #: 06100230
Trans ID: 306347781530233
APPR CODE: 061970
VISA Manual CNP
.....4965

AMOUNT \$2,000.00

APPROVED

I AGREE TO PAY ABOVE TOTAL AMOUNT
IN ACCORDANCE WITH CARD HOLDER'S
AGREEMENT
MERCHANT AGREEMENT (IF CREDIT VOUCHER)
RETAIN THIS COPY FOR STATEMENT
VERIFICATION

MERCHANT COPY

Entire Document
NON-CONFIDENTIAL

3336 0000 0313 9320 6696 9460

Martin, Thornton E

From: Ward, Beth A
Sent: Wednesday, December 14, 2016 2:02 PM
To: Adkins, Sandra K
Cc: McKeone, Beverly D; Martin, Thornton E
Subject: RE: WV DAQ Permit Application Status for West Virginia University; HSC Campus
Attachments: 2016_12_14_14_00_47.pdf

Please see the attached receipt.

OASIS CR 1700063575

Thank You!

From: Adkins, Sandra K
Sent: Friday, December 09, 2016 12:05 PM
To: gayle.fratto@mail.wvu.edu; 'brian.lemme@mail.wvu.edu' <brian.lemme@mail.wvu.edu>
Cc: McKeone, Beverly D <Beverly.D.Mckeone@wv.gov>; Martin, Thornton E <Thornton.E.Martin@wv.gov>; Ward, Beth A <Beth.A.Ward@wv.gov>
Subject: WV DAQ Permit Application Status for West Virginia University; HSC Campus

**RE: Application Status
West Virginia University
HSC Campus
Facility ID No. 061-00230
Application No. R13-3352**

Gayle Fratto,

Your application for a construction permit for the Health Science Center Campus was received by this Division on December 8, 2016, and was assigned to Lee Martin. The following items were not included in the initial application submittal:

Original affidavit for Class I legal advertisement not submitted.

Application fee AND/OR additional application fees:

**\$1,000 Construction, Modification, Relocation or Temporary Permit*

**\$1,000 NSPS*

(You may contact the Accounts Receivable section at 304 926-0499 ext. 4888 or Beth Ward at ext. 1846 to pay via credit card. DEP accepts Visa and MasterCard only.)

These items are necessary for the assigned permit writer to continue the 30-day completeness review.

Within 30 days, you should receive a letter from Lee stating the status of the permit application and, if complete, given an estimated time frame for the agency's final action on the permit.

Any determination of completeness shall not relieve the permit applicant of the requirement to subsequently submit, in a timely manner, any additional or corrected information deemed necessary for a final permit decision.

Should you have any questions, please contact the assigned engineer, Lee Martin, at 304-926-0499, extension 1212.

Adkins, Sandra K

From: Adkins, Sandra K
Sent: Friday, December 9, 2016 12:05 PM
To: 'gayle.fratto@mail.wvu.edu'; 'brian.lemme@mail.wvu.edu'
Cc: McKeone, Beverly D; Martin, Thornton E; Ward, Beth A
Subject: WV DAQ Permit Application Status for West Virginia University; HSC Campus

**RE: Application Status
West Virginia University
HSC Campus
Facility ID No. 061-00230
Application No. R13-3352**

Gayle Fratto,

Your application for a construction permit for the Health Science Center Campus was received by this Division on December 8, 2016, and was assigned to Lee Martin. The following items were not included in the initial application submittal:

Original affidavit for Class I legal advertisement not submitted.

Application fee AND/OR additional application fees:

**\$1,000 Construction, Modification, Relocation or Temporary Permit*

**\$1,000 NSPS*

(You may contact the Accounts Receivable section at 304 926-0499 ext. 4888 or Beth Ward at ext. 1846 to pay via credit card. DEP accepts Visa and MasterCard only.)

These items are necessary for the assigned permit writer to continue the 30-day completeness review.

Within 30 days, you should receive a letter from Lee stating the status of the permit application and, if complete, given an estimated time frame for the agency's final action on the permit.

Any determination of completeness shall not relieve the permit applicant of the requirement to subsequently submit, in a timely manner, any additional or corrected information deemed necessary for a final permit decision.

Should you have any questions, please contact the assigned engineer, Lee Martin, at 304-926-0499, extension 1212.

Entire Document
NON-CONFIDENTIAL